

BlueWave[®] 75 Rev 2.0

UV Light-Curing Spot Lamp System



BlueWave[®] 75 (PN 40077-International/PN 40078-North American) shown with 4-pole lightguide

Operation Manual

TABLE OF CONTENTS

Unpacking and Inspection	Page 3
Safety	Page 4-7
Description	Page 7
Specifications	Page 8
Installation and System Interconnect.....	Page 9
Settings and Adjustments	Page 10
Intensity Adjustment.....	Page 10
Intensity Validation	Page 10
Intensity Control	Page 10
Setting the Cycle Duration	Page 11-12
Lamp Dual-Hour Meter	Page 12
Bulb Replacement.....	Page 13-14
Operation	Page 15
Maintenance	Page 16
Troubleshooting	Page 17
Frequently Asked Questions.....	Page 18-19
Spare Parts List	Page 20
Options/Accessories	Page 21
Definition of Terms.....	Page 22
Warranty	Page 23

The enclosed BlueWave® 75 UV Light-Curing Spot Lamp System was developed and manufactured by the DYMAX team, driven by a desire to best serve your needs. Before shipping, your *BlueWave 75* was thoroughly checked and tested for trouble-free performance.

The proper setup and operation of this system will maximize safety and user-friendly performance, providing optimum yield of your technological process.

THEREFORE, WE ENCOURAGE YOU TO READ, UNDERSTAND, AND FOLLOW ALL SAFETY AND OPERATING INSTRUCTIONS AND RECOMMENDATIONS COMPILED IN THIS AND OTHER RELATED MANUALS prior to setting up and operating this new spot-lamp system or its individual components.

Par conséquent, nous vous encouragez à lire, comprendre, et suivre toute sécurité et instructions d'opération et recommandations rédigées dans cette et autres manuels établis un lien avant de mettre en place et de faire fonctionner ce nouveau système de lampe de tâche ou ces composants individuels.

If you encounter a problem, have any questions, or would like to help us with your suggestions or recommendations, please contact our Applications Engineering or Customer Service Departments. Trained DYMAX professionals are standing by to serve you.

Si vous rencontrez un problème, avez n'importe de questions, ou si vous voudrez de nous aider avec vos suggestions ou recommandations, s'il vous plaît contactez notre département technique ou service client à 860-482-1010. DYMAX formés professionnels attendent à vous servir.

UNPACKING AND INSPECTION

Upon receipt of the unit, carefully remove the contents from the boxes and check for damage. **DYMAX is not responsible for damage from shipping – all claims for shipping damage should be made with the carrier.**

Check all boxes for contents and write down any serial numbers for further reference. You may wish to retain original shipping cartons in case you need to repackage any item for return.

If you observe or experience any problem with your equipment, notify DYMAX Customer Service, your authorized distributor, or your DYMAX representative immediately.




Figure 1. *BlueWave 75* Unpacking Diagram

NOTE: Units are shipped with the Bulb/Reflector installed.

Before continuing with the installation, please read the following chapters of this manual for safety recommendations and installation, operation, and troubleshooting instructions.



CAUTION! Always wear proper eye protection when working with this unit, which emits high-intensity ultraviolet and visible energy! Note: The rear of the unit also emits stray UV & Visible energy.



WARNING! Always observe safety requirements!



CAUTION! Risk of electrical shock if cover is removed!



CAUTION! Cover is warm to the touch when unit is in operation!



PRÉ-CAUTION! Toujours faire de l'usage des lunettes de protection ou protéger de visage marche près du devant d'élément!



AVERTISSEMENT! Remmarquez toujours besoin de sécurité!



PRÉ-CAUTION! Risque de décharge électrique quand le couvert est enlever!



PRÉ-CAUTION! Le couvert est chaud a le touche quand l'élément est en opération!



ACHTUNG! Tragen Sie immer eine Sicherheitsbrille oder einen Gesichtsschutz, wenn Sie nahe an der UV Lichtquelle arbeiten. Die Rückseite des Gerätes emittiert gestreutes UV Licht!



WARNHINWEIS! Bitte beachten Sie immer die Sicherheitshinweise!



ACHTUNG! Gefahr eines Stromschlages bei geöffnetem Gehäuse!



ACHTUNG! Gehäuse erwärmt sich während des Betriebs: Vorsicht bei Berührung!

SAFETY

Equipment is designed to be used properly setup, with components correctly connected, and operated in accordance with relevant instructions. Design was developed to maximize operator safety and minimize exposure to UV.

SAFETY RECOMMENDATIONS:

- Use the provided safety eyewear or an approved face shield for eye/face protection.
- Long-sleeved shirts or a lab coat are recommended to protect arms and the use of UV opaque gloves will protect the hands.

NOTE: The BlueWave[®] 75 emits UVA and visible light. Never look directly into the lightguide entrance fitting or end of lightguide while the unit is on.

Sécurité

L'équipement être conçu pour être utilisé correctement constituer, avec composants brancher correctement, et marché en conformément avec instructions important. Le plan était développer pour rendre au maximum opérateur sécurité et minimiser exposition à ultraviolette.

RECOMMANDER DE SÉCURITÉ:

- Emploi lunettes, ou un protecteur de visage pour protection de ultraviolet pour protéger vos yeux.
- Chemises à manche long, ou manteau de labo, sont recommander pour protéger les bras, et utilisation de ultraviolette gants opaque vais protéger les mains.

REMARQUER: avec le filtre intérieur installé, l'Onde Bleu émettre lumière. Ne jamais regardez directement à la source de lumière pendant que l'élément est en opération.

SICHERHEITSHINWEISE

Dieses Gerät wurde so entwickelt, dass es nur vollständig, alle Komponenten korrekt miteinander verbunden, in Übereinstimmung mit relevanten Instruktionen betrieben wird. Bei der Entwicklung wurde weiterhin großen Wert auf die Benutzersicherheit und minimale UV Belastung gelegt.

SICHERHEITSHINWEISE:

- Tragen Sie immer die mitgelieferten Sicherheitsbrille oder speziellen Gesichtsschutz, der Ihre Augen vor UV Licht schützt.
- Wir empfehlen Langarm - Hemden oder einen Laborkittel zu tragen, um die Arme zu schützen. Für die Hände empfehlen wir UV- geblockte Handschuhe.

BITTE BEACHTEN SIE: Durch den installierten inneren Filter strahlt die *BlueWave 75* und sichtbares Licht aus. Schauen Sie deshalb niemals direkt in die Lichtquelle, wenn das Gerät angeschaltet ist.

UV LIGHT-CURING SYSTEM SAFETY CONSIDERATIONS

DYMAX light-curing technology has been used successfully for over 30 years. The fast cure, one-component nature of our curing technology has made it the process of choice for many manufacturers requiring a "cure on demand" assembly process. There are four common questions/concerns related to light-curing systems: UV exposure, high-temperature surfaces, ozone, and bright, visible light.

UV EXPOSURE

Standard DYMAX UV light-curing systems have been designed to primarily emit UVA light (as shown in Chart 1). UVA light is generally considered the safest of the three UV ranges: UVA, UVB, and UVC. Although OSHA does not currently regulate ultraviolet-light exposure in the workplace, the American Conference of Governmental Industrial Hygienists (ACGIH) does recommend Threshold Limit Values (TLV's) for ultraviolet light. The strictest interpretation of the TLV (over the UVA range) for workers' eyes and skin is 1 mW/cm² (intensity), continuous exposure. Unless workers are placing bare hands into the curing area, it is unusual to exceed these limits. To put 1 mW/cm² limit into perspective, cloudless summer days in Connecticut regularly exceed 3 mW/cm² of UVA light and which includes the more dangerous UVB light, primarily responsible for sun tans, sun burns, and skin cancer.

The human eye cannot detect "pure" UV light, only visible light. A radiometer should be used to measure stray UV light to confirm the safety of a UV-curing process. A workstation that exposes an operator to more than 1 mW/cm² of UVA continuously should be redesigned.




Chart 1. Spectrum of Light

Light-curing technology can be a regulatory compliant, “worker-friendly” manufacturing process when the proper safety equipment and operator training is utilized. There are two ways to protect operators from UV exposure: shield the operator and/or shield the source.

SHIELD THE OPERATOR

- **UV-Blocking Eye Protection** – UV-blocking eye protection is recommended when operating UV-curing systems. Both clear and tinted UV-blocking eye protection is available from DYMAX.
- **UV-Blocking Skin Protection** – Where the potential exists for UV exposure upon skin, opaque, UV-blocking clothing, gloves, and full-face shields are recommended.

SHIELD THE SOURCE OF UV LIGHT

Any substrate that blocks UV light can be used as a shield to protect workers from stray UV light. The following materials can be used to create simple shielding structures:

- **Sheet Metal** – Aluminum, steel, stainless steel, etc. Sheet metal should be coated black or black anodized to minimize reflection of UV and visible light toward operators.
- **Rigid Plastic Film** – Transparent or translucent, UV-blocking plastics (typically polycarbonate or acrylic) are commonly used to create shielding where some level of transparency is also desired.
- **Flexible Film** – Translucent UV-blocking, flexible urethane films can be used to quickly create workstation shielding. This UV-blocking, flexible urethane film is available from DYMAX.

HIGH-TEMPERATURE SURFACES

Surfaces exposed to high-intensity curing lights will rise in temperature. The intensity, distance, exposure time, cooling fans, and the type/color of the surface can all affect the actual rise in surface temperature. In some cases, exposed surfaces can reach temperatures capable of producing a burn or causing damage to a substrate. In these cases, care must be taken to ensure either a more moderate surface temperature or appropriate protection/training for operators.

OZONE

Standard DYMAX bulbs (UVA type) generate an insignificant amount of UVC and therefore essentially no ozone. Some UV light-curing systems, like those used to cure UV inks, emit primarily “shortwave” (UVB and UVC) energy. Upon exposure to UVC energy (specifically <240 nm), oxygen molecules (O_2) split into oxygen atoms (O) and recombine with O_2 to create ozone O_3 . The current, long-term ozone concentration limit recommended by ACGIH, NIOSH, and OSHA is 0.1 ppm ($0.2\text{mg}/\text{m}^3$).

BRIGHT, VISIBLE LIGHT

The bright, visible light energy emitted by curing systems can cause eyestrain if proper eye protection or shielding is not used. Tinted eye protection and/or opaque/tinted shielding can be utilized to address this concern.

SUMMARY

UV-light sources can be more “worker friendly” than many commonly accepted industrial processes, provided the potential concerns are addressed. Both the lower working temperature and lack of spurious frequency transmission that this system produces, make it even more user friendly. Contact your DYMAX representative for information regarding the proper use of DYMAX light-curing systems.

DESCRIPTION

The BlueWave® 75 is a high-intensity, UV light-curing spot lamp used for the curing of adhesives, coatings, and potting materials. It emits UV light from a lightguide. This guide can be hand-held for complete mobility or fixtured into position for repetitive operations or in automated equipment.

The unit consists of an anodized aluminum housing, containing an electronic Power Supply, circuit protection, Bulb/Reflector Assembly, internal Light Filter, thermostatically-controlled Cooling Fan, Lightguide Mount, Bulb and unit status indicator lights, combination resettable and non-resettable hour-meter, and shutter system. A thermal shutdown sensor is provided for internal temperature control of the unit. A Cover-Closed Switch and Lightguide-Sensing Switch add to the safety of the unit. Fan filters should be changed or cleaned frequently to prevent blockage and reduced ventilation airflow. Electric Shutters are supplied with timed and manual shutter operating modes. The Lightguide is separate and plugs into the Lightguide entrance fitting on the front panel (the forward facing Lightguide Mount).

An Intensity Control Feature allows operators to adjust output intensity during process validation and production. Users can now manually adjust intensity to compensate for Bulb degradation and to maintain an optimized output or allow it to emit direct line of sight energy to unprotected personnel.

CAUTION: Once the Lightguide is engaged there exists the possibility of light emitting if the unit is triggered. Never look directly into the Lightguide.

A Cooling Fan is provided to keep the Bulb Housing and internal components of the Power Supply at the optimum operating temperature. The fan or exhaust opening must not have any restriction in their airflow path. The UV source is a 75-Watt short-arc Bulb mounted in a reflector and pre-focused to provide optimum light output. The unit is rated for continuous operation.

The blue Indicator Light, located above the Lightguide Mount, lights when the bulb is operating. The Power Supply operates on line voltages between 100 and 240 VAC and frequency between 50 and 60 Hz.

If the Bulb extinguishes due to a momentary power failure the unit must be turned off and allowed to cool 20 minutes before attempting to re-ignite the Bulb. Arc-type bulbs are designed to (and prefer) to be run continuous. Repeated on/off cycling decreases Bulb life and accelerates intensity degradation. It is good practice to leave the unit running for a full 8-10 hour shift and only turn the unit off if it will be off for more than a few hours or overnight.

SPECIFICATIONS

Part Number	PN 40078 – North American Version (with 115V standard plug) PN 40077 – International Version (with no plug)
Intensities*	Total (280-450 nm) 19+ W/cm ² Visible (400-450 nm) 9+ W/cm ² UVA* (320-395 nm) 9+ W/cm ² UVB (280-320 nm) 1.5+ W/cm ²
Power Requirements	100-240 VAC, 50/60 Hz, 1.0 Amps
Power Supply	Solid State, 75 Watt
Bulb	75 Watt arc bulb (included)
Reflector	Elliptical; glass with dichroic coating to reflect UV and minimize IR
Shutter Timer	Digital LED timer up to 99.99 seconds; manual or timed shutter
Shutter Activation	Footswitch
Cooling	Filtered, thermally-controlled single fan configuration
Operating Conditions	Temperature range 2-38°C, humidity limit – non-condensing
Hour Meter	Digital LCD; Total unit operating hours (non re-settable) Total Bulb hours (re-settable)
Housing Dimensions	12" x 12.25" x 6.5" (30.5 cm x 31.1cm x 16.5 cm)
Weight	14 lbs. (6.0 kg)
System Warranty	1 year from date of purchase
Bulb Warranty	2,000 hours (no intensity warranty, only Bulb ignition)
Replacement Bulb	PN 40205

* Measured with an ACCU-CAL™ 50 radiometer using a lightguide simulator and standard internal "Cool Blue" filter.




Figure 2. BlueWave 75 Front Panel

INSTALLATION AND SYSTEM INTERCONNECT

1. Connect power cord to back of unit and plug into a grounded wall outlet.
2. Connect the footswitch to the connection in the back of the unit. A ground stud is provided on the back of the unit if additional grounding is desired.
3. Remove the protective end caps from the Lightguide (purchased separately). Visually inspect the two ends to verify that no foreign material is present. The DYMAX liquid-filled Lightguide ends can be cleaned with isopropyl alcohol as required to remove oils and debris. Attach the Lightguide by removing the shipping cap covering the Lightguide Mount opening and then inserting the Lightguide as shown in Figure 4 and 5. Lightly tighten the setscrew on the Lightguide Mount to secure the Lightguide.

NOTE: Do not over tighten the setscrew as permanent and non-warranty damage will result.

4. Turn the power switch to ON.
5. Allow Bulb to warm up (~5 minutes). The unit is warmed-up when the blue “unit ready” indicating light is illuminated and two beeps sound. The Shutter is inoperable until warm-up is complete and a lightguide is installed.

NOTE: If the unit is coming on from an extreme cold condition ($<0^{\circ}\text{C}$) the system fan will come on to initiate a warming cycle and the unit ready LED will pulse as ambient air ($>2^{\circ}\text{C}$) is being circulated through the unit. Once the internal temp is $>2^{\circ}\text{C}$ the Bulb will ignite and the normal warm-up cycle will commence.

6. Operate the Shutter by pressing the Footswitch. With the Shutter Selector Switch in the manual position, the Shutter operates directly from the Footswitch and will remain open as long as the switch is depressed. In the timed position, the Shutter open duration is determined by the setting on the electronic timer. A momentary depression of the Footswitch will initiate the timed cycle and the Shutter will remain open for the duration of the cycle (the counter will count down the time until the Shutter closes).
7. With the Shutter open, adjust the Intensity Adjustment Screw as required to achieve the desired output intensity. The output intensity can be measured using an ACCU-CAL™ 50 Radiometer or equivalent.

CAUTION: This is an arc Bulb (not a filament Bulb). Once ignited, it must be left on for a minimum of 10 minutes to vaporize elements in the Bulb. If not, re-ignition of the Bulb may be difficult or unreliable.

NOTE: The Bulb must cool before it can be re-ignited. Turn the unit off and allow 20 minutes for it to cool down. If the Bulb fails to ignite, refer to the “Troubleshooting” section of this manual. Bulb life is reduced each time the unit is switched on. Avoid repeated cycles that shorten bulb life by leaving unit on through breaks.




Figure 3. Cable Connections



Figure 4-5. Lightguide Connection

SETTINGS AND ADJUSTMENTS

INTENSITY ADJUSTMENT

A DYMAX ACCU-CAL™ 50 Radiometer can be used to set and monitor the unit's intensity output. If the BlueWave® 75's output intensity needs adjustment, use the Intensity Adjustment Knob. This knob installs into the Intensity Adjustment Screw (see Figure 6) using the M2 screw included with the unit. A small screwdriver (included) can also be used to adjust the intensity (see Figure 7). If it is undesirable to allow the operator easy access to the intensity adjustment, it is recommended that the Intensity Adjustment Knob not be attached.

Turning the Intensity Adjustment Knob fully clockwise will provide full intensity out the lightguide. As the Intensity Adjustment Knob is turned counter-clockwise the intensity will slowly be reduced.



Figure 6. Intensity Adjustment Knob



Figure 7. Adjusting Intensity with Screwdriver

INTENSITY VALIDATION

Prior to production, DYMAX advises customers to conduct testing to determine the time and intensity required to fully cure their resin in their specific application. Typically, users validate by one of the following methods:

- **Set Exposure Time, Determine Intensity:** Users can specify a cure time and through empirical testing, determine the intensity required to achieve full cure. As with any manufacturing process, it is advisable to incorporate a safety factor.
- **Set Intensity, Determine Exposure Time:** Users can specify intensity and through empirical testing, determine the exposure time required to achieve full cure. As with any manufacturing process, it is advisable to incorporate a safety factor.

INTENSITY CONTROL

Process validation confirms a minimum acceptable intensity. Users can then choose to operate at full intensity (using the excess intensity as an additional safety factor) or maintain a constant intensity through periodic manual adjustments.

BlueWave 75 bulbs will typically vary less than 1% over eight hours of normal use and so daily or weekly adjustments are adequate to maintain a tightly controlled process. A “Change Bulb” Indicator Light is provided to alert the operator to check Bulb operation or to change the Bulb if required.

SETTING THE CYCLE DURATION

The Shutter Timer located on the front panel of the BlueWave® 75 is factory set to the most common operating mode and recommended operation of the Shutter Timer with the *BlueWave 75*. Some modes available on this Shutter Timer may not operate correctly with the *BlueWave 75* unit and have been disabled.

The Shutter Timer has an LCD display and keypad. The LCD display has a reset indicator, key protect indicator, output indicator, preset value, set value, and timing operation indicator. A brief description of each display and location:



Figure 8. Shutter Timer

- **RST [Reset Indicator]** – Active when the Shutter Timer is reset by pressing the “RST” Button (Reset Button) on the lower left face of Shutter Timer.
- **K/P [Key Protect]** – Will always be lit as the function of the Shutter Timer is programmed at the factory and locked before shipment.
- **OUT [Output Indicator]** – Displayed when relay is switched on; is not displayed when relay is switched to off.
- **RST [Reset] Button** – Located in the lower left corner of the Shutter Timer. Pressing this button will reset the Shutter Timer.
- **Timing Value** – Four-digit segmented display in center of the Shutter Timer. Shows current status of time.
- **Set Value** – Four-digit segmented display in lower right corner of the Shutter Timer. Shows set length of time.

In addition to the indicators, the Shutter Timer contains six buttons with their functions described as follows:

- **MODE** – Disabled at the factory and locked before shipment.
- **Reset Indicator (RST)** – Used to cancel out of a timed cycle. If a cycle is initiated and counting down, pressing this button will close the Shutter and reset the counter to the current preset.
- **Digit Increment 1-4:** Pressing these buttons up or down will increment or decrement that digit by one. The timer digits are formatted MM:SS for a maximum Shutter time of 99 minutes and 0.99 seconds. Consult DYMAX for information on changing the format of this Timer.

To set the Shutter open duration, press the appropriate up/down button until the corresponding digit increments in the set value. By pressing the key labeled (1, Figure 8), it will increment the left most digit on the set value. By pressing the key labeled (2, Figure 8), it will increment the second digit of the set value and similar for digits 3 and 4. The small grey buttons are “rocker” style so pressing the top half increments the digit up while pressing the bottom half will increment down. The Timer will increment from 9 back to 0. The Timer comes programmed for a range of 00.01 seconds to 99.99 seconds. Consult factory for other time ranges and functions.

To operate the Timer, select the “Timer” operation mode on the front panel (large rocker switch left of the Timer module). Program the time into the Timer as described above and depress the Footswitch. The Shutter will open and the preset value will begin to count backward. When the Timer reaches 00.00, it will reset the value to the set value and close the Shutter. The Timer can be stopped once started by pressing the RESET button on the lower left face of the timer. If power is removed from unit, the Timer will reset to set value.

LAMP DUAL-HOUR METER

The Lamp Dual-Hour Meter (Figure 9) provides elapsed time of unit operation (top display), as well as Bulb usage (bottom display). The top display (Elapsed-Time Meter) continues to count hours of operation on the unit and cannot be reset. The lower display reflects the number of hours on the Bulb. Bulb hours should only be reset when a new Bulb is installed. Instructions for Bulb replacement are found in this manual as well as being located on the sticker under the unit cover next to where the Bulb is located.

When the Lamp Hour Meter reaches 2,000 hours, the bulb will turn off and the Hour Meter will alternate between “CHANGE BULB” and “2000.0”. The unit will not operate until a new Bulb is installed as described in the Bulb replacement section of this manual.

WARNING: Operating a *BlueWave 75* Lamp beyond 2,000 hours may result in a non-passive failure of the Lamp! Do not reset the Lamp Hour Meter without replacing the Bulb.



Figure 9. Lamp Dual-Hour Meter

BULB REPLACEMENT

1. Unplug the unit. Remove the top cover from the BlueWave® 75 by loosening the four cover fasteners (these are the four extended screws on the sides of the top cover).
2. Unplug the Bulb Connector and loosen the two knurled screws shown in Figure 10. Pivot the white Bulb Clamp up and out of the way to allow removal of the Bulb.




Figure 10. Bulb Replacement Step 1-2

3. Gently tip the back end of the Bulb down to unseat the top edge and remove the Bulb.
4. Using powder free gloves, unpack the new Bulb (PN 40205). Take care not to bend the flat electrode in the center of the Bulb.
5. Orient the new Bulb so the Side Electrode Wire is positioned at the side of the housing that is open (Figure 11). Carefully seat the bottom edge as shown in Figure 12. The lower Retaining Spring Wire will exert resistance that you will need to overcome as you seat the Bulb. With the lower edge seated, tip the top edge into the upper seat. The Bulb will remain in place if properly installed.
6. Pivot the white Bulb Clamp in place and tighten the two knurled screws. Plug in the Bulb Connector. (See Figure 13).




Figure 11. Bulb Replacement Step 3




Figure 12. Bulb Replacement Step 5




Figure 13. Bulb Replacement Step 6

7. Replace the unit's cover and tighten the four cover fasteners. Once the cover is secure, power up the unit and using a small screw driver press the Reset Button located on the back of the unit. This will reset the Bulb Hour Meter but not extinguish the LED Change Bulb Light. Cycle the system power once to reset the LED Change Bulb Light.

NOTE: Fan Filters (included with replacement bulbs) **MUST** also be replaced during a Bulb change.



Figure 14. Bulb Replacement Step 7

8. Once the new Bulb is installed and operational, it is recommended that the intensity is set again (see Settings and Adjustments Instructions).

OPERATION

1. The BlueWave[®] 75 will arrive almost fully assembled. Please refer to Installation and System Interconnect for installation of the lightguide, power cord, and footswitch. The system should be positioned in a dry location that does not obstruct airflow from the rear of the unit.

NOTE: Do not block the vents at the rear of the unit. Allow a minimum of 12" [150 mm] clearance from the back vents to the nearest obstructing surface.

2. Follow the procedures for connecting the power cord, footswitch, lightguide, and additional grounding wire (if necessary).
3. Follow the steps to set the desired intensity and shutter cycle duration.
4. The lightguide can be hand held, fixed over the curing area using an optional Lightguide Mounting Stand (PN 39700), or fixtured using custom tooling. The UV and visible light emitted from a lightguide diverges. As a result, the intensity decreases and the curing area increases with distance from the end of the lightguide. Figure 15 shows this relationship for the 5-mm liquid lightguide. Values given are for general reference; actual intensities can be measured using a radiometer.
5. Apply the proper DYMAX product for the application, fixture if necessary, and cure using the *BlueWave 75*.

NOTE: For additional information on light-curing systems, refer to DYMAX LIT010 – Guide to Selecting and Using DYMAX Light-Curing Systems and LIT008 – Comprehensive Guide to DYMAX Light-Curing Technology.




Figure 15. Curing Area/Intensity VS. Distance using a 5-mm Lightguide

MAINTENANCE

The BlueWave® 75 was designed to operate with minimum maintenance and following basic steps below will assure continued top performance.

LIGHTGUIDE

Clean the lightguide ends monthly or as required. The ends of the lightguide should be kept clean to transmit as much energy as possible. Cured adhesive can be removed with a razor blade. Avoid tight radius bends of the lightguide since this will reduce output and may cause permanent damage to the guide.

FAN FILTERS

The external Fan Filters should be inspected and cleaned periodically to prevent dust buildup from affecting airflow through the unit. Spare Fan Filters are provided with each unit and with replacement Bulbs. The Fan Filters are washable and may be reused. Remove the Fan Filter by removing the snap-on cover from the rear of each Grill.




Figure 16. Fan Filter Replacement

FUSE REPLACEMENT

The unit has two Fuses that are installed in the Power Receptacle. To remove the Fuses, unplug the unit and remove the Fuse Holder with a small screwdriver (Figure 17). Remove the Fuses from the Fuse Holder and install new Fuses. Replace the Fuse Holder into the Power Receptacle (Figure 18 & 19).



Figure 17. Power Receptacle



Figure 18. Fuse Holder



Figure 19. 4.0 Amp Fast-Acting Fuse (PN 37869)

TROUBLESHOOTING

WARNING: Only qualified maintenance personnel should attempt the following procedures.

AVERTISSEMENT: Seulement personnel d'entretien diplômé devrais essayer les procedures suivant.

Problem	Possible Cause	Testing	Corrective Action
Bulb will not ignite or Change Bulb Light is on	Improper connections	Visually inspect all input/output connections (i.e. power cord, Bulb).	Secure all connections.
	Bulb is beyond useful life of 2,000 hours	Replace with a new Bulb/Reflector Assembly. Reset Bulb Hour Meter and re-test unit.	Replace Bulb/Reflector Assembly if required. Typical Bulb life is 2,000 hours.
	Main line Fuse blown (nothing in unit operates)	Remove Fuse from Power Receptacle and check with an Ohmmeter.	Replace Fuse, if defective.
Low output intensity/ fails to cure adhesive in allotted time	Bulb beyond useful life	Use a Radiometer (DYMAX ACCU-CAL™ 50 or equivalent) to measure output intensity.	Replace Bulb/Reflector Assembly if beyond useful life.
	Transmission loss in Lightguide too great	Compare Lightguide output against new Lightguide (or use the DYMAX Lightguide Simulator) to determine transmission loss.	Inspect and clean guide ends, and eliminate tight bends. Replace Lightguide.
	Contaminants on Lightguide	Visually examine ends of Lightguide for contaminants.	Clean with isopropyl alcohol or equivalent. Heavy deposits on liquid Lightguides may be carefully removed using a razor blade. Replace the Lightguide if it cannot be cleaned.
	Bulb/Reflector Assembly not installed properly	Visually check to make sure the Bulb/Reflector Assembly is seated flush in the Bulb Mount Assembly (any error in installation could cause a low output)	Properly install Bulb/Reflector Assembly.

FREQUENTLY ASKED QUESTIONS

Q.) My BlueWave® 75 will not turn on.

- A.) Check the power cord connection.
- B.) Check the Fuses located where the Power Cord plugs into the unit.
- C.) If a tone is heard, the Cover Interlock Sensor may not be closed. Verify that the cover is properly closed and that the four side securing screws are tightened. Remove the cover and verify nothing is preventing it from fully seating on the unit.

Q.) The blue lens on the front panel does not light.

- A.) This signifies the Bulb has not ignited. Check that the power cord and Bulb connections are secure.

Q.) The Bulb will not ignite, it only “flickers”.

- A.) Replace the Bulb. Excessive power cycling will shorten the life expectancy of the Bulb. This is an arc, not filament Bulb. Once ignited, it must be left on for a minimum of 10 minutes to vaporize elements in the Bulb. If not, the Bulb may be difficult to re-ignite.

Q.) I installed a new Bulb, and it still will not ignite.

- A.) The *BlueWave 75* has a safety shutdown feature at 2,000 hours. If the equipment has reached the safety shutdown point, "CHANGE BULB" and "2000.0" will alternate on the Hour Meter and the Bulb will not light. When this happens, the *BlueWave 75* will no longer supply an ignition voltage until a new Bulb is installed and the Reset Switch is pressed on the back of the equipment. The power must be on for this reset to be performed. The Reset Switch should always be pressed whenever a new Bulb is installed and a Bulb should never be operated after it reaches the 2,000 hour life expectancy.
- B.) Check and make sure the Bulb Connector is fully seated into the Igniter.

Q.) Why do I have low intensity, even with a new Bulb?

- A.) Standard *BlueWave 75* units have an Optical Filter installed, which filters the energy before it reaches the Lightguide. The intensity may be decreased if the light that passes through the Filter is restricted by dust and debris accumulated on the Filter surfaces.
- B.) The intensity is being checked too early. The 75W Bulb will not reach full intensity until at least five minutes after initial power up.
- C.) The Lightguide may not be fully seated into the Lightguide Mount.
- D.) The end of the Lightguide may have a build-up of adhesive or outgassing residue. Carefully remove with isopropyl alcohol or a razor blade for heavier deposits.
- E.) The condition of the Lightguide will also affect the intensity. All Lightguides degrade with time, but intensity will also drop if the Lightguide is bent or kinked. The intensity reading from the Lightguide should be compared to the intensity reading from a Lightguide Simulator to determine the efficiency.
- F.) The Bulb is not installed correctly. Bulb orientation is vital during the installation of the Bulb. Refer to the Bulb installation instructions supplied with all new 75W Bulbs for the proper installation procedure.

Q.) My Footswitch is not operating.

- A.) Check the connection of the Footswitch into the unit. Check that the Lightguide is fully installed and that the “Lightguide Seated” indicating light is on.

Q.) What causes my Shutter to hesitate to open or close?

- A.) Maintaining clean equipment and a clean working environment will help prevent the build up of dust and other debris from collecting on the mechanical parts of the BlueWave[®] 75. Debris that settles in the piston well (Adjustment Screw) can hinder the movement of the Shutter Solenoid Piston.
- B.) Shutter alignment to Reflector Mount incorrect.
- C.) The Shutter is a mechanical part which may wear after extended use.
- D.) The alignment of the Shutter to the Bulb Mount Assembly is incorrect.

Q.) Why does my *BlueWave 75* seem to run very hot?

- A.) Replace the Fan Filter Media on the Exhaust Fan and vent located in the back of the equipment. This is your first line of defense against airborne dust and debris. This Fan Filter Media is supplied with new Bulbs and should be changed regularly.
- B.) Ideal operation of this equipment suggests at least 12" of clearance behind the unit for proper ventilation. Confirm that the Intake Fan is not feeding from the exhaust of other equipment.
- C.) Confirm that the cooling fan is operating.
- D.) The unit may already be full of dust and debris and over heating the internal electronics.

SPARE PARTS

Item	Part #
Bulb/Reflector Assembly	40205
Fuses: F4.0 Amp	37869
Fan Filter and Holder	38587
Fan Filter Media	38659
Clip, Spring, Lower	39609
Clip, Reflector Upper (Teflon)	38548
Fan 24 VDC	40204
Feet (Rubber Bumper)	38572
Filter, Bandpass	35986
Filter, Dual Fuse IEC AC Inlet	37178
Footswitch	40402
Harness to Hour Meter	40728
Hour Meter (unit serial #s 5121800 and higher)	40730
Power Supply, 75W Assembly	40089
Shutter Guide	40224
Spring, Solenoid Plunger	40309
Shutter, Tear-Drop, SS	40313
Lightguide and Lamp Mount Assembly	40054
Switch, Manual Timer	36654
Switch, Power	36288
Timer, Digital	36287
PCB Temp Sensor	40099
Shield, Temp. Sensor	40419




Figure 20. Bulb Assembly Part Numbers

OPTIONS/ACCESSORIES

Item	Part #
BlueWave® Case with Foam	38679
Liquid-D Lightguide, 5 mm X 1 Meter	5720
Liquid-D Lightguide, 5 mm X 1.5 Meter	5721
Liquid-D Lightguide, 8 mm X 1 Meter	5722
Liquid-D 2-Pole Lightguide, 3 mm X 1 Meter	38476
Liquid-D 3-Pole Lightguide, 3 mm X 1 Meter	38477
Liquid-D 4-Pole Lightguide, 3 mm X 1 Meter	38478
Fiber Optic 2-Pole Lightguide, 3 mm x 1 Meter	39783
Fiber Optic 3-Pole Lightguide, 3 mm x 1 Meter	39787
Fiber Optic 4-Pole Lightguide, 3 mm x 1 Meter	39791
DYMAX ACCU-CAL™ 50 Radiometer (Spot Model)	39560
Lightguide Simulator	38408
Lightguide Mounting Stand	39700
Additional liquid and fiber optic single- and multi-pole lightguide configurations are available. Contact DYMAX for assistance.	Contact DYMAX

DEFINITION OF TERMS

Bulb - Light source generating ultraviolet, visible, and infrared radiant energy from burning matter stimulated by electrical power conditioned by a proper power supply which is an integral part of a Lamp. A light source is usually placed into a Reflector (of various geometry) to increase light source efficiency by collecting and directing radiant energy of selected spectra (for a given curing process).

Intensity - a measure of energy over the unit of surface area (measured in W/cm^2 or mW/cm^2). This measure is also referred to as “irradiance”.

Brightness, also known as **Luminance** - description of energy in the visible region of the spectrum (approximately from 400 to 700 nm) and recorded in photometric units. “**Intensity**” (see below) of visible light energy is called Luminance.

Luminance - luminous flux (energy of visible light) incident per unit area, and measured in **Lx** (lux) or **Lumen/cm²**.

Ultraviolet (UV) - The invisible region of the spectrum just beyond the violet end of the visible region. Wavelength ranges in general from 1.0 to 400 nm. DYMAX bulbs (burners) do not radiate energy in deep ultraviolet; there are very minute amounts below 220 nm and practically nothing can be sensed below 200 nm. This is due to the use of an ozone-blocking quartz-bulb envelope (See Ozone).

1. **Ultraviolet A (UV-A)** - UV of long wavelength from within approximately 400 to 320 nm of the spectral band (4000 to 3200).
2. **Ultraviolet B (UV-B)** - UV of medium wavelength from within approximately 320 to 280 nm.
3. **Ultraviolet C (UV-C)** - UV of short wavelength below 280 nm (we say from 280 to 200 nm) – a large amount of this energy is present in the sunlight.
4. **Visible** - Light that can be seen 400-700 nm.

Dose - is irradiance integrated over time, or Irradiance (W/cm^2) x Time (s) = Dose (Joules/cm²). Note: Watt is the power that gives rise to the production of energy at the rate of 1-joule (J) per second (s).

Ozone - oxidizing agent (O_3) produced by the action of Ultraviolet radiant energy (below 185 nm) or electrical corona discharge of oxygen on air.

OSHA 1910.145: “Regulation of Accident prevention Signs and Tags” defines the following headers as:

WARNING – is used when there is a hazardous situation that has some probability of severe injury.

CAUTION - is used to indicate a hazardous situation that may result in minor or moderate injury.

NOTICE - is used to convey a message related directly or indirectly to the safety of personnel, or protection of property.

OSHA 1910.145: “Regulation de la prevention d’accident Signes et Étiquettes” défin les têtes comme:

WARRANTY

CAUTION!

DYMAX CORPORATION RESERVES THE RIGHT TO INVALIDATE ANY WARRANTIES, EXPRESSED OR IMPLIED, DUE TO ANY REPAIRS PERFORMED OR ATTEMPTED ON DYMAX EQUIPMENT WITHOUT WRITTEN AUTHORIZATION FROM DYMAX. THOSE CORRECTIVE ACTIONS LISTED BELOW ARE LIMITED TO THIS AUTHORIZATION.

DYMAX offers a one-year warranty against defects in material and workmanship on all system components *with proof of purchase date*. Unauthorized repair, modification, or improper use of equipment may void warranty. The use of aftermarket replacement parts not supplied or approved by DYMAX Corporation will void any effective warranties and may result in damage to the equipment.

REPLACEMENT BULB WARRANTY

If the Bulb fails to ignite during the warranty period of 2,000 hours and all Bulb History Cards for a specific BlueWave® have been returned to DYMAX, the bulb will be replaced under warranty.

© 2009-2011 DYMAX Corporation. All rights reserved. All trademarks in this guide, except where noted, are the property of, or used under license by DYMAX Corporation, U.S.A.

Please note that most dispensing and curing system applications are unique. DYMAX does not warrant the fitness of the product for the intended application. Any warranty applicable to the product, its application and use is strictly limited to that contained in DYMAX's standard Conditions of Sale. DYMAX recommends that any intended application be evaluated and tested by the user to insure that desired performance criteria are satisfied. DYMAX is willing to assist users in their performance testing and evaluation by offering equipment trial rental and leasing programs to assist in such testing and evaluation. Data sheets are available for valve controllers or pressure pots upon request.

MAN016 PN40153 9/27/2011

DYMAX Corporation
860.482.1010
info@dymax.com
www.dymax.com

DYMAX Europe GmbH
+49 (0) 611.962.7900
info_de@dymax.com
www.dymax.de

**DYMAX UV Adhesives &
Equipment (Shenzhen) Co Ltd**
+86.755.83485759
dymaxasia@dymax.com
www.dymax.com.cn

**DYMAX Asia
(Hong Kong) Ltd**
+852.2460.7038
dymaxasia@dymax.com
www.dymax.com.cn

DYMAX Korea LLC
82.2.784.3434
info@dymax.kr
www.dymax.co.kr

